

Job or Customer :	
Location :	
Engineer :	
☐ Complies with Spec ☐ Alternate	Notes :
Contractor :	
HeatLink Rep :	
Submitted By :	Date :
Approved By :	Date :
P.O. Number :	Date :

Description

Add an automatic air vent to a 76100 or 76200 series 1-¼" stainless steel manifold by replacing a valve.

Technical Data

Material:..... Brass
 Operating Temperature:..... 160°F (70°C)
 Maximum Temperature:..... 230°F (110°C)
 Minimum Temperature:..... 32°F (0°C)

Qty	Stk. #	Weight
	76932	0.44 lb (0.2 kg)

Installation


Installation must follow all of HeatLink's instructions and guidelines.

Maintenance

Maintenance must follow all of HeatLink's instructions and guidelines.

Related Documents

- HeatLink Limited Heating Warranty



This page is intentionally blank.